






NOTE:

1. 25 mm THICK & 26kg/m³ DENSITY FOAM GLUED TO ALL INSIDE FACIES OF WALLS, DOORS, COLUMNS, RADIATOR/ALTERNATOR DUCTS, TOP/BOTTOM BEAMS, ROOF AND Baffle PLATES IN ALTERNATOR SIDE EXCEPT PUNCH AREA.
2. USE ONLY Zn WITH BLUE PASSIVATED FASTENERS.
3. CANOPY PARTS SHALL BE POWDER COATED IN PE BLUE STRUCTURE FINISH EXCEPT ROOF, BASE FRAME AND PUNCH MESH WHICH ARE IN RAL 5000 STRUCTURE FINISH.
4. SHEET THICKNESS FOR ALL CANOPY PARTS ARE IN 1.2mm THK CRCA SHEET.
5. SHEET THICKNESS FOR PRESSED CHANNELS IN MAIN FRAME: CRCA 3mm & HR 4mm THICK.
6. ALL JOINTS BETWEEN ROOF, COLUMNS AND TOP BEAMS ARE SHALL BE PASTED WITH 25 mm WIDTH BY 3mm THICK NOISE INSULATING TAPE TO AVOID NOISE LEAKAGES.
7. TOLERANCE ON OVER ALL DIMENSIONS IS ± 20 mm.
8. ALL DOORS RUBBER BEADING BULB DIA. 12mm.
9. ALL EXTERNAL FASTENERS, CANOPY LOCKS & HINGES ARE IN STAINLESS STEEL.



UNDIMENSIONED TOLERANCES				DIMENSIONS			
mm	inch	mm	inch	mm	inch	mm	inch
0	0	0	0	0.5	0.020	0.5	0.020
1	0	1	0.040	1	0.040	1	0.040
3	0.125	3	0.125	3	0.125	3	0.125
6	0.250	6	0.250	6	0.250	6	0.250
12	0.500	12	0.500	12	0.500	12	0.500
25	1.000	25	1.000	25	1.000	25	1.000
30	1.180	30	1.180	30	1.180	30	1.180
50	2.000	50	2.000	50	2.000	50	2.000
75	3.000	75	3.000	75	3.000	75	3.000
100	4.000	100	4.000	100	4.000	100	4.000
150	6.000	150	6.000	150	6.000	150	6.000
200	8.000	200	8.000	200	8.000	200	8.000
250	10.000	250	10.000	250	10.000	250	10.000
300	12.000	300	12.000	300	12.000	300	12.000
400	16.000	400	16.000	400	16.000	400	16.000
500	20.000	500	20.000	500	20.000	500	20.000

REVISIONS		SIGNATURE		DATE	
1	ISSUED FOR APPROVAL				
2	ISSUED FOR PRODUCTION				

DESIGN INFORMATION		REVISIONS		SIGNATURE		DATE	
1	DESIGN	1	ISSUED FOR APPROVAL				
2	CONSTRUCTION	2	ISSUED FOR PRODUCTION				

TITLE: G.A. DRAWING OF ACOUSTIC D.G. SET-32.5 KVA/M5

SCALE: 1:1

PROJECT NO.: 12503414R0000C

DRAWN BY: D.G. SET-32.5 KVA/M5

CHECKED BY:

DATE:

12503414R0000C

12503414R0000C

12503414R0000C

12503414R0000C